

No: 08 / 2024

Date: 09 May 2024



## AIRPORT EMERGENCY SERVICE

---

# FIRE PREVENTION CIRCULAR

---

To All F&B Operators

### PREVENTION OF ELECTRONIC EQUIPMENT FIRE

This circular serves to notify all F&B operators of a recent dishwasher fire incident caused by an internal short circuit due to water intrusion.

2 All F&B operators are requested to inspect their dishwasher for similar issue. In addition, electronic equipment are required to be serviced periodically according to the manufacturer's recommendations for prevention of defects leading to fire.

3 For reference past circulars, please visit <https://www.changiairport.com/corporate/e-services/documents.html>.

4 You may reach out to the Fire Prevention Section of the Airport Emergency Service via phone at 6541-2535 or email to [fire.safety@changiairport.com](mailto:fire.safety@changiairport.com) for further enquiries.

A handwritten signature in black ink, appearing to read "Peter Ng".

Peter Ng  
Head, Fire Prevention Section  
Airport Emergency Service