

**CHECKLIST FOR UNDERGROUND SEWERAGE & SANITARY SERVICE
DIVERSION WORKS IN CHANGI/SELETAR AIRPORT**

Objective: To carry out a thorough & complete sewerage & sanitary service protection and/or diversion works at the subject site

Item: **Check boxes when Completed**
(or indicate as “Nil” if not applicable or required)

1. Engage qualified registered & competent contractor of the relevant trade & work head
 2. Engage Registered Plumber(LP) registered under Singapore Plumbing Society(PS) , who holds a valid water service plumber licence
 3. Consult CAG EDG Civil Team and/or PUB(WRN)/NEA to obtain approval or written clearance on proposed works in vicinity of existing sewerage system(within influence zone or 25m corridor for sewers & 36m for DTSS)
 4. Have a copy and follow latest Guideline & comply with PUB’s Advisory Notes on:
-“General Requirements for the Protection of Sewers”
-“Prevention of Damage to the Sewerage System”
 5. Engage PUB registered CCTV contractor to carry out and submit pre & post construction CCTV inspections & reports(with CCTV video(DVD)) for any existing/new sewer within or adjacent to development lot to PUB(WRN)
 6. Engage Registered Surveyor to verify/set out/peg & prepare endorsed setting out plan for sewer alignment, pile positions, TERS alignment etc on site
 7. Ensure no utilities services(cable, gas pipe, water pipe etc) shall over-cross/undercross within 1m from outer edge of sewers unless written clearance from CAG EDG Civil Team and/or PUB(WRN) is obtained before any works at site
-

-
8. If reuse of existing sanitary/sewerage system is required – a thorough investigation by qualified person to ensure adequate capacity & good condition and an endorsed inspection report is to be submitted to CAG EDG Civil Team and/or PUB(WRN)
9. Coordinate with CAG EDG Civil Team and/or PUB(WRN) for sewerage diversion services to be carried out by PUB(WRN)
10. To notify or report to FMC, CAG EDG Civil Team, CAG Project Officer and/or PUB-24 Hour Call Centre hotline at **1800-2846600** immediately should any sewerage service be damaged, exposed or any sealing work is required
-

Applicant

Approval by CAG

Name of PD/Mgr: _____

Name of Project Officer: _____

Signature/Date: _____

Signature/Date: _____

Supported by Consultant:

Name of QP: _____

Signature/Date: _____