

No : 07 / 2020  
Date : 16 September 2020  
Rescission Date : NA



---

## AIRPORT EMERGENCY SERVICE

---

# FIRE PREVENTION CIRCULAR

---

To All Private Developers

### **NOTIFYING AES BEFORE AND AFTER ANY FIRE ALARM ISOLATION, TESTING, WORKS**

Presently, the electrical fire alarm system(s) installed in your building(s) shall have been connected to the SCDF's Operations Centre through an approved alarm monitoring company as per the [SCDF Fire Code 2018](#) under Chapter 6.3 on Electrical Fire Alarm System, *para 6.3.1* and *6.3.2* (click the link to be redirected to the SCDF Fire Code).

2 AES may still conduct initial fire-fighting and rescue operations at any incident site within Changi Airport until SCDF arrives. This remains true even after the fire alarm signal at your premises have been connected to the SCDF DECAM.

3 As the electrical fire alarm system(s) installed in your building(s) is still connected to AES Watchroom, we would like to inform you that:

- a) AES should be notified of any fire alarm isolation, testing, works, etc to prevent unnecessary turnouts of emergency resources and;
- b) Triggered or isolated fire alarms should be returned to normal mode as soon as possible for the safety of your building(s), and AES Watchroom should be informed at 6541 2526 once completed.

4 For further clarifications, you may contact the Fire Prevention Section (FPS) of the Airport Emergency Service at 6541 2535 or e-mail to: [fire.safety@changiairport.com](mailto:fire.safety@changiairport.com).

A handwritten signature in black ink, appearing to read "Addison Low".

ADDISON LOW  
Head, Fire Prevention Section  
Airport Emergency Service